

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0075:0195 Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: FIRE-LITE ALARMS INC., ONE-FIRE-LITE PLACE, NORTHFORD, CT 06410
Contact: Brian Reynolds (203) 484-6124 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Models H350, H355, and H355HT fixed temperature heat detectors. Models H350R and H355R rate-of-rise with fixed temperature heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: H350, H355, and H355HT 135° F fixed temperature
H350R and H355R 15° F rate-of-rise
H355HT 190° F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible fire alarm control units.

NOTE:

Rev. 05-06-05JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division