

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0075:0212 Page 1 of 1

CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

LISTEE: FIRE-LITE ALARMS INC., ONE-FIRE-LITE PLACE, NORTHFORD, CT 06410
Contact: Brian Reynolds (203) 484-6124 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Models ACC-25/50DA and ACC-25/50DAZS Distributed Audio Panel. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:
FC-MGM: Message Generator Module
ACC-AAM25: Audio Amplifier Module
FC-XRM70: Vrms Converter Module
FC-LPS: Local Playback Speaker
FC-MIM: Microphone Interface Module
ACC-ZSM: Zone Splitter Module
ACC-ZPM: Zone Page Module

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name; model number; electrical ratings; date of manufacture, by week, month or quarter and year and UL Inc. Label

APPROVAL: Listed as voice communication systems for use with separately listed compatible fire alarm control units to provide emergency voice evacuation signals. Refer to listee's Installation Instruction Manual for details.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

07-20-06 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division