

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0075:0217

Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: FIRE-LITE ALARMS INC., ONE-FIRE-LITE PLACE, NORTHFORD, CT 06410
Contact: Brian Reynolds (203) 484-6124 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Models MS-9600LS and MS-9600UDLS addressable fire alarm control units. Suitable for local protective, remote, auxiliary, and central station signaling when used with appropriate optional modules and additional separate listed equipment. The panels provide one signaling line circuit for connection of up to 318 total addressable devices (159 detectors and 159 modules); two Class A or four Class B notification appliance circuits; three form C relays are provided that are default programmed for alarm, trouble, and supervisory relay outputs. The MS-9600UDLS come with the DACT-UD2 factory installed. Refer to listee's data sheet for detailed product description and operational considerations. System components:
MS-9600LS, MS-9600UDLS Control Unit
SLC-2LS Loop Card
DACT-UD2 Digital Alarm Communicator Transmitter Modules
4XTMF Transmitter Module
LDM-32F Lamp driver Module
ACM-8RF Control Relay Module
ANN-RLY Remote Relay
ANN-80 , ANN-LED, LCD-80F Remote Annunciator
ACM-16ATF, ACM-32AF Remote Annunciator
AEM-16ATF, AEM-32AF Remote Annunciator
ACC-25/50ZST Audio Command Center (Listing No. 6911-0075:207)

RATING: 120 VAC, 50/60 Hz, 3.0 amps

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and FM label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. *Also suitable for high-rise applications for use with Model ACC-25/50ZST Audio Command Center (Listing No. 6911-0075:207). Refer to manufacturer's Installation Manual for details.
This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. These control units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal as required per NFPA 72, 2002 Edition.
This control unit meets the requirements of UL-864, 9th Edition Standard

*Rev. 06-24-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division

NOTE:

1. For Fire Alarm Verification Feature (Delay of fire alarm), the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.
2. Combined with 7170-0075:220

*Rev. 06-24-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**Listing Expires **June 30, 2011**Authorized By: **FRANCIS MATEO**, Program Coordinator*Fire Engineering Division*